City of Riverside Fire Department

INCIDENT INFORMATION FACT SHEET



Incident Name: Brisbane

Incident Location: 19559 Brisbane Drive

Type of Incident: Residential Structure Fire

Incident Number: 12-25624

Date Reported: 11/23/2012

Time Reported: 7:59 PM

Fatalities: 0 Critical: 0 Moderate: 0 Minor: 0 Non Injury: 0

Transported Ground Ambulance(s): 0

Loss: \$0

Save: \$0

Cause: Under Investigation

Control Time:

Evacuations: No.

Evacuation Comments:

RESOURCES ASSIGNED

Fire Fighters: 20

Engine Companies: 3

Truck Companies: 2

Overhead Personnel: 1

Ambulance(s): 0

Water Tenders: 0

Utilities: No

Red Cross: No

Displaced Persons: No

CURRENT SITUATION

Specialized Equipment:

(Recent updates are posted at the top of Current Situation)

Riverside Fire units responded to multiple reports of a single family residence on fire. The first arriving unit reported the interior of the attached garage was well involved with fire and the occupant reported all occupants had evacuated the residence. The fire was contained to the garage. The structure was built with a residential fire sprinkler system and 2 sprinklers activated and assisted in preventing the fire from spreading and causing additional damage. The cause of the fire is under investigation.

COOPERATING AGENCIES

Information Center: 951-826-5321 Prepared By: B.Bock Date/Time Posted: 11/23/2012 0711 Follow us on Twitter: RIVCAFIRE