City of Riverside Fire Department

INCIDENT INFORMATION FACT SHEET



Incident Name: 12th Street

Incident Location: 3877 12th Street

Incident Number: 13-00255

Date Reported: 01/04/2013

Time Reported: 3:12 AM

Type of Incident: Structure Fire

Fatalities: 0 Critical: 0 Moderate: 0 Minor: 0 Non Injury: 0

Transported Ground Ambulance(s): 0

Loss: \$0 **Save:** \$0

Cause: Electrical

Control Time: 01/04/2013 0415

Evacuation Comments:

Evacuations: No.

RESOURCES ASSIGNED

Fire Fighters: 34

e Fighters: 34

Truck Companies: 3

Engine Companies: 4

Ambulance(s): 0

Overhead Personnel: 2

Water Tenders: 0

Utilities: No

Red Cross: No

Displaced Persons: No

CURRENT SITUATION

Specialized Equipment:

(Recent updates are posted at the top of Current Situation)

City of Riverside Fire Department units responded at 3 am to a fire alarm at a downtown office building. Upon arrival firefighters found a three story business office with fire visible on the first floor and lapping up the exterior of the building to the second and third floors. Fire crews made a rapid interior attack and were able to keep the fire contained to the room of origin, which was an office on the first floor. Due to construction features, the fire traveled to the second floor and third floor thru the interior walls. Crews were able to remove the drywall covering on the offices directly above the involved office and keep the fire extension to a minimum. After completing the investigation to determine cause, it was determined to be electrical in nature. The building was equipment with a fire alarm which activated and created a response for the fire department. The early notification by the fire alarm accompanied with the rapid response of the fire department prevented a building and contents loss of approximately \$2 million dollars. There were no injuries to occupants or fire personnel.

COOPERATING AGENCIES

Prepared By:

Date/Time Posted: 01/04/2013 1448

Information Center: 951-826-5321

Follow us on Twitter: RIVCAFIRE