



FIRE APPARATUS AT GATES

DATE: January 4, 2011

INFORMATION BULLETIN: B-11-002

APPROVED BY: M. Esparza

2010 California Fire Code Section 503 – Fire Apparatus Access Roads

Sec. 503.6 Security Gates

Fire Apparatus access roads shall have an unobstructed width of not less than 12 feet at any gated access and an unobstructed width of 20 feet after passing through access gates. Knox key switches or locks shall be required for all vehicular gated access and be sub-mastered for both fire and police emergency access. Electric gates shall be required to automatically open from the inside by use of a sensor or other approved means.