



## **FIRE FLOW REQUIREMENTS FOR BUILDINGS**

**DATE:** January 4, 2011

**INFORMATION BULLETIN:** D-11-001

**APPROVED BY:** M. Esparza

### **2010 California Fire Code, Appendix B, Section B105.2**

2010 California Fire Code, Appendix B, Section B105.2 is modified to read: The minimum fire flow and flow duration for buildings other than one and two family dwellings shall be as specified in Table B105.1

Exception: A reduction of 50 percent is allowed when the building is provided with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. The resulting fire flow shall not be less than 1,500 gallons per minute for the prescribed duration as specified in Table B105.1