



CITY OF RIVERSIDE FIRE DEPARTMENT

Incident Information Fact Sheet



Incident Name: Reynolds Incident
Incident Location: 3900 Reynolds St

Type of Incident: Commercial Structure Fire
Incident Number: 17-23479
Date Reported: 08/12/2017
Time Reported: 7:37 PM

Fatalities: 0 **Critical:** 0 **Moderate:** 0 **Minor:** 0 **Non Injury:** 0
Transported Ground Ambulance(s): 0
Loss: \$0
Save: \$0
Cause: Arson

Control Time: 08/12/2017 2118

Evacuations: No
Evacuation Comments:

RESOURCES ASSIGNED

Fire Fighters: 10	Overhead Personnel: 1	Utilities: No
Engine Companies: 2	Ambulance(s): 0	Red Cross: No
Truck Companies: 1	Water Tenders: 0	Displaced Persons: No
Specialized Equipment:		

CURRENT SITUATION

(Recent updates are posted at the top of Current Situation)

The City of Riverside Fire Department responded to a report of commercial structure fire at the County of Riverside Department of Social Services in the 3900 block of Reynolds Rd. The call had originally come in as a fire alarm, but when the first engine company arrived, they discovered the front door forced open, and smoke coming from the interior. The captain immediately requested a full structure response. Fire crews entered the structure and found evidence of vandalism. They also discovered one automatic sprinkler head that had gone off and contained the fire to the office area where a chair and other material had been ignited. Firefighters searched the entire 21,000 square foot office building looking for any occupants, and any other signs of fire. Once the building had been searched, the sprinkler system was shut down, and fire crews began remove large amounts of water from the building. The city of Riverside Fire Departments Arson Task Force responded and investigated the suspicious fire. A representative from the County of Riverside arrived and took over the cleanup effort. There were no civilian or firefighter injuries as a result if the incident.

COOPERATING AGENCIES

Riverside Police