

CITY OF RIVERSIDE FIRE DEPARTMENT





Incident Name: Magnolia

Incident Location: 10082 Magnolia Ave

Incident Number: 1221369

Date Reported: 10/01/2012

Type of Incident: Structure Fire

Time Reported: 11:07 AM

Control Time:

Fatalities: 0 Critical: 0 Moderate: 0 Minor: 0 Non Injury: 0

Transported Ground Ambulance(s): 0

Loss: \$0

Save: \$0 Evacuations: No

Cause: Evacuation Comments:

RESOURCES ASSIGNED

Fire Fighters: 20 Overhead Personnel: 1 Utilities: No

Engine Companies: 2 Ambulance(s): 0 Red Cross: No

Truck Companies: 2 Water Tenders: 0 Displaced Persons: No

Specialized Equipment:

CURRENT SITUATION

(Recent updates are posted at the top of Current Situation)

City of Riverside Fire units arrived to light smoke showing from a commercial building. Firefighters investigated the cause of the smoke and had found a small smoldering fire in the attic area. Cause of the fire was due to contractors repairing the roof using a small torch to ignite materials. Damage was contained to a small area. All occupants were allowed to return to the building.

COOPERATING AGENCIES

Prepared By: B.Bock Information Center: 951.826.5321

Date/Time Posted: 10/01/2012 1459 Follow us on Twitter: rivcafire