



BENCH MARK:
 2.5 SPURS IN P.P.#498-J 50' WESTLY OF E SPRUCE
 ST. ON EAST SIDE OF CHICAGO AVE.
 ELEV. 911.765

QUANTITY ESTIMATE
 4" VITRIFIED CLAY PIPE 156 LF.
 PAVEMENT REPLACEMENT 100 SF.
 4" SADDLES 4 EA.

1. Construction shall be in accordance with the City of Riverside Department of Public Works, Standard Specifications for Standard Drawings.
2. It shall be the responsibility of the contractor to clear the right of way in accordance with the provisions of the law as it affects each utility facility and irrigation lines, appearance and structure of the City.
3. Joints in vitrified clay pipe sewers shall conform to ASTM Standard Specification 15.001, or the latest revision thereof.
4. Pipe shall be bedded per Case 11, Standard Drawing No. 457, unless otherwise specified on plan.
5. Location of wyms and laterals to be determined in the field.
6. All stubs and laterals to be constructed in accordance with Standard Drawing No. 962. Stubs shall be plugged and covered.
7. Manhole frames and covers to be set to existing pavement grades.
8. Laterals are to be 4" and extended to property line.
9. Prior to construction of sewer, Contractor is to expose existing sewer and contact Engineer for verification of existing utility lines.

* AS BUILT 7-10-65 HB

ALBERT A. WEBB ASSOCIATES CIVIL ENGINEERS RIVERSIDE, CALIFORNIA APPROVED BY: <i>E. L. Yeager</i> DATE: 7/4/65 R.E. No. 9876 W.O. 64-444 FOR: E. L. YEAGER F.B. 589		CITY OF RIVERSIDE, CALIFORNIA DEPARTMENT OF PUBLIC WORKS APPROVED BY: <i>[Signature]</i> DATE: 4-20-65 OFFICE ENGINEER PARK DEPARTMENT DIRECTOR OF PUBLIC WORKS TRAFFIC DIVISION ASSISTANT CITY ENG.		PROJECT NO. S-228A SHEET 1 OF 1 FILE NO. 64-444 B
DESIGNED BY: <i>[Signature]</i> DRAWN BY: <i>[Signature]</i> CHECKED BY: <i>[Signature]</i>		DATE: 4-22-65 HORIZ. SCALE: 1" = 50' VERT. SCALE: 1" = 5'		

Indexed Bob S.