



- GENERAL NOTES:**
1. All wyes and laterals to be located in the field. All man holes to be Riverside City Standard No. 500, unless otherwise noted on plan. Maximum vertical spacing of steps in all manholes shall be 12".
 2. All laterals to be _____ and extended to the property line. Laterals to be constructed in accordance with Standard Drawing No. 562.
 3. All construction shall be in accordance with Standards and Specifications _____ of the City of Riverside Department of Public Works. Pipe shall be bedded per Code _____ Standard Drawing No. 522.
 4. It shall be the responsibility of the Contractor to clear the Right of Way in accordance with the provisions of law as it affects each utility including irrigation lines and appurtenances, and at no extra cost to the City of Riverside.
 5. Joints in vitrified clay pipe sewers shall conform to A.S.T.M. Standard C-425-607, or the latest revision thereto.

J. F. DAVIDSON - CIVIL ENGINEER
 R.E. NO. 893
 RIVERSIDE, CALIFORNIA
 APPROVED BY *G.F. [Signature]* DATE 12-21-63

CITY OF RIVERSIDE, CALIFORNIA
 DEPARTMENT OF PUBLIC WORKS

SEWER PLAN & PROFILE
EASEMENT

RECORD OF SURVEY N^o 739
 HORIZ. SCALE 1"=40' VERT. SCALE 1"=4'

REVISIONS	
DATE	DESCRIPTION

NO. 5-522
 4/21/64