



Bench Mark: Chiseled cross on NW corner of irrigation box at SE corner of Canyon Crest Drive and Monte Vista Drive. Elev. - 1086.08

NOTE: SEE RIV CITY PLAN NO. S-354 FOR LATERAL CONNECTION TO LOT 9

- GENERAL NOTES:**
1. All wyes and laterals to be located in field. All manholes to be Riverside City Std No. 500, unless otherwise noted on plans. Maximum vertical spacing of steps in all manholes shall be 12".
 2. All laterals shall be 4" and extended to the property line.
 3. All construction shall be in accordance with Standards and Specification No. 460 of the City of Riverside Dept of Public Works. Pipe shall be bedded per Case II, Standard Drawing No. 452.
 4. It shall be the responsibility of the Contractor to clear the Right of Way in accordance with the provisions of law as it affects each utility including irrigation lines and appurtenances, and at no extra cost to the City of Riverside.
 5. Joints in vitrified clay pipe sewers shall conform to ASTM Standard C425-60T or the latest revision thereto.
 6. All stubs and laterals to be constructed in accordance with Std Drwa. No. 562. Stubs shall be capped and plugged.

J. F. DAVIDSON ASSOCIATES
 CIVIL ENGINEERS - SURVEYORS - PLANNERS
 RIVERSIDE, CALIFORNIA
 APPROVED BY: *George M. Cat* DATE: 9/23/64
 R.E. No. 10688

CITY OF RIVERSIDE, CALIFORNIA
 DEPARTMENT OF PUBLIC WORKS
 APPROVED BY: *[Signature]* DATE: 9-8-65
 OFFICE ENGINEER
 PARK DEPARTMENT
 TRAFFIC DIVISION
 ASSISTANT CITY ENG.

SEWER PLAN AND PROFILE
 LA MART DRIVE
 EL CERRITO DRIVE
 TRACT 3008
 HORIZ. SCALE: 1" = 50'
 VERT. SCALE: 1" = 5'

PROJECT NO.
NO. S-585
 SHEET 1 OF 1
 FILE NO. 2767

★ AS BUILT HB 7-6-65

W.O. 12315 FOR: MEG Inc. DESIGNED BY: FB-897 DRAWN BY: FW CHECKED BY: R & S