



**BENCH MARK:**  
Spike in S.P. # 2526-1 on the East side Myers  
South of Rudisill Elev. 823.72, F.B. 553/61

Remove and replace pavement from right  
edge of Sewer trench to left edge exist. pav.

Note: No connections from M.H.'s, to  
and, until sewer is extended to M.H.

**QUANTITY ESTIMATE**

10" Vitrifed Clay Pipe	1,043 LF.
Manhole Standard No. 500	3 EA.
Pavement Replacement	1,543 LF.
10" x 6" Wyes	2 EA.

- REVISIONS**
1. Construction shall be in accordance with the City of Riverside Department of Public Works, Standard Specifications for Sewer and Storm Drainage.
  2. It shall be the responsibility of the contractor to check the right of way, and determine with the appropriate authority, the location of all existing and proposed utility lines, and to locate and mark them.
  3. All construction shall be in accordance with the City of Riverside Department of Public Works, Standard Specifications for Sewer and Storm Drainage.
  4. The contractor shall be responsible for obtaining all necessary permits and for the cost thereof.
  5. The contractor shall be responsible for the cost of all utility relocation and for the cost of all utility relocation.

★ AS BUILT 3-24-66 HB

<b>ALBERT A. WEBB ASSOCIATES</b> CIVIL ENGINEERS RIVERSIDE, CALIFORNIA APPROVED BY <i>Emmet N. Webb</i> DATE 5/13/65 R.E. No. 3876		<b>CITY OF RIVERSIDE, CALIFORNIA</b> DEPARTMENT OF PUBLIC WORKS APPROVED BY <i>[Signature]</i> DATE 7-14-65 DIRECTOR OF PUBLIC WORKS ASSISTANT CITY ENG. <i>[Signature]</i> DATE 7-14-65		ACCT. NO. 5090 <b>PROJECT NO.</b> <b>S-623</b> SHEET 1 OF 1 FILE NO. 65-122-B
W.045-122 FOR ALBETHWOOD ENTERPRISES, B. 553		DESIGNED BY <i>BEI</i> DRAWN BY <i>BEI</i> CHECKED BY <i>REC</i>		HORIZ. SCALE: 1" = 50' VERT. SCALE: 1" = 5'