



BENCH MARK:
120'x 200' IN P.P. # 6329024 AT N.W.
CORNER OF JACKSON ST. & COLORADO AVE.
ELEV. 749.53

QUANTITY ESTIMATE

8" VITRIFIED CLAY PIPE	290 L.F.
MANHOLE - STD. DWS. 5.00	1 EA.
PAVING REPLACEMENT	400 S.F.
8" x 4" WYES	4 EA.

- GENERAL NOTES**
- Construction shall be in accordance with the City of Riverside, Department of Public Works, Standard Specifications No. 461 and Standard Drawings.
 - It shall be the responsibility of the contractor to clear the right of way in accordance with the provisions of the law as it affects such utility including irrigation lines and appurtenances and at no cost to the City.
 - Joints in vitrified clay pipe sewers shall conform to ASTM Standard C-425-50T, or the latest revision thereof.
 - Pipe shall be bedded per Case 11, Standard Drawing No. 452, unless otherwise specified on plan.
 - Location of wyes and laterals to be determined in the field.
 - All stubs and laterals to be constructed in accordance with Standard Drawing No. 562. Stubs shall be plugged and capped.
 - Manhole frames and covers to be set to existing pavement grades.
 - Laterals are to be 4" and extended to property line.
 - Prior to construction of sewer, Contractor is to expose existing sewer and contact Engineer for verification of existing elevations.

FILE COPY RECEIVED
NOV 3 1965
ORIGINAL NOT SIGNED
DUE TO LACK OF EASEMENT,
DEPT. OF PUBLIC WORKS

Not BUILT! *Waly*

ALBERT A. WEBB ASSOCIATES CIVIL ENGINEERS RIVERSIDE, CALIFORNIA		CITY OF RIVERSIDE, CALIFORNIA DEPARTMENT OF PUBLIC WORKS		PROJECT NO. S-627
APPROVED BY _____ DATE _____ R.E. No. _____	MARK _____ REVISIONS _____ APPR. DATE _____	OFFICE ENGINEER _____ BY _____ DATE _____ PARK DEPARTMENT _____ TRAFFIC DIVISION _____ ASSISTANT CITY ENG. _____	APPROVED BY _____ DIRECTOR OF PUBLIC WORKS _____ DATE _____	SHEET 1 OF 1 FILE NO. 64-406 B
W.O. 64-406 FOR FIRST PAPERIST CLARK & ARLINGTON, P.B. 551		DESIGNED BY <i>AW</i> DRAWN BY _____ CHECKED BY <i>AW</i>		SEWER PLAN AND PROFILE CHAMBER STREET AUDREY AVE. TO SOUTHEASTERY R.S. 874 HORIZ. SCALE: 1" = 50' VERT. SCALE: 1" = 5'