



GENERAL NOTES

- CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION, 1973 EDITION AND CITY OF RIVERSIDE STANDARD DRAWINGS.
- IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO CLEAR THE RIGHT OF WAY IN ACCORDANCE WITH THE PROVISIONS OF THE LAW AS IT AFFECTS EACH UTILITY INCLUDING IRRIGATION LINES AND APPURTENANCES AND AT NO COST TO THE CITY.
- PIPE SHALL BE BEDDED PER STANDARD DRAWING NO. 452, CASE 2, UNLESS OTHERWISE SPECIFIED ON THE PLAN.
- MANHOLE FRAMES AND COVERS TO BE SET BY SEWER CONTRACTOR AFTER FINISH PAVING OF THE STREET.
- PRIOR TO CONSTRUCTION OF SEWER CONTRACTOR IS TO EXPOSE EXISTING SEWER AND CONTACT THE ENGINEER FOR VERIFICATION OF STUB ELEVATION.
- AT ALL HOUSE LATERAL OR SEWER MAIN CROSSINGS OF WATER MAINS, SHOWN ON THE PLAN, THE SEWER SHALL BE ENCASED WITH TYPE "C" ENCASEMENT PER STD. DWG. CWD-023 FOR 4.50' EACH SIDE OF WATER MAIN.
- LATERALS ARE TO BE 4" VCP AND EXTENDED TO THE PROPERTY LINE.
- ALL STUBS AND LATERALS TO BE CONSTRUCTED IN ACCORDANCE WITH STANDARD DRAWING NO. 562. STUBS TO BE PLUGGED WITH A REMOVABLE PLUG.
- LOCATION OF WYES AND LATERALS SHALL BE DETERMINED AT THE DIRECTION OF THE OWNER OR AS SHOWN ON THE PLAN.
- A PLUG SHALL BE INSTALLED AND WILL REMAIN IN PLACE WHERE THE NEW SEWER CONNECTS WITH THE EXISTING SEWER UNTIL SUCH A TIME THAT THE NEW SEWER IS ACCEPTED BY THE CITY.
- IF THE SEWER BETWEEN ARLINGTON AND STATION 6+50.30 DOES NOT EXIST AT TIME OF CONSTRUCTION THE CONTRACTOR SHALL INSTALL A REMOVABLE PLUG AT LOW END OF PROP. SEWER. NO CONNECTIONS TO THIS LINE WILL BE ALLOWED UNTIL THE LINE FROM ARLINGTON PER PLAN S-992 IS BUILT.

NOTICE TO CONTRACTOR

THE EXISTENCE AND LOCATION OF ANY UNDERGROUND UTILITY PIPES OR STRUCTURES SHOWN ON THIS PLAN WERE OBTAINED BY A SEARCH OF THE AVAILABLE RECORDS. TO THE BEST OF OUR KNOWLEDGE, THERE ARE NO EXISTING UTILITIES EXCEPT AS SHOWN ON THESE PLANS.

THE CONTRACTOR IS REQUIRED TO TAKE DUE PRECAUTIONARY MEASURES TO PROTECT THE UTILITY LINES SHOWN AND ANY OTHER LINES NOT OF RECORD OR NOT SHOWN ON THIS PLAN.

CURVE DATA				
No.	R	Δ	T	L
①	280'	14°24'10"	34.38'	70.38'
②	304'	21°48'10"	58.55'	115.68'
③	300'	21°48'10"	57.75'	114.16'

ALBERT A. WEBB ASSOCIATES
 CIVIL ENGINEERS
 RIVERSIDE, CALIFORNIA

APPROVED BY: *[Signature]* DATE: 12/17/74
 R.E. No. 21884

W.O.74-223 FOR: Art McCullom F.B.1035

APPROVED BY: *[Signature]* DATE: 12-13-74
 CHIEF WATER UTILITY ENGINEER

CITY OF RIVERSIDE, CALIFORNIA
 PUBLIC WORKS DEPARTMENT

APPROVED BY: *[Signature]* DATE: 1/6/75
 DIRECTOR OF PUBLIC WORKS

DATE: 1-6-75

SEWER PLAN AND PROFILE
SANDY LANE
 BETWEEN ARLINGTON AVE. AND VALLEY DR.
 PARCEL MAP 202

ACCOUNT No. _____
 DRAWING NUMBER
S-990
 SHEET 1 OF 1
 74-223-B

SCALE: Horiz. 1" = 40', Vert. 1" = 4'