



Notes:

1. Enclosure is to be furnished complete with grates, covers, tamper proof vents and stainless steel penta head bolts.
2. Covers shall be painted, after fabrication, with one coat of rust proof primer and one coat of aluminum paint.
3. Installation per UGS-761

DRAWN: \_\_\_\_\_  
 CHECKED: *[Signature]*  
 APPROVED: *[Signature]*  
 DATE: 9-10-98

UNDERGROUND STRUCTURES STANDARDS  
 COMMERCIAL SUBSURFACE TRANSFORMER  
 ENCLOSURE (5' X 8'-6" X 7')  
 REQUIREMENTS

UGS-760